

**SOUTHERN ARIZONA TESTING LABORATORY**  
**P.O. BOX 2508**  
**TUCSON, AZ 85702-2508**  
**(520) 623-3331**  
**May 14, 2007**

For: CLAY MINE ADOBE  
6401 WEST OLD AJO WAY  
TUCSON, AZ 85746

Project: April 2007 – Adobe Mortar Mix

Received: 4/25/2007  
Concrete Contractor:

Submitted by: Eric Johnson

Contractor:

Address of Project:

Arch./Engr.:

Source of Sample:

Concrete Co.:  
Truck No.:  
Ticket No.:  
Temp:

Mix: Adobe Mortar Mix  
Admix:  
Batch Size:  
Water Added:  
Time:

**REPORT OF MORTAR CUBE TESTS**

Lab. No.	Identification No.	Flow	Date Made	Date Tested	Age (Days)	Lbs./Sq. Inch
20429		110	4/27/2007	5/04/2007	7	380
20480		110	4/27/2007	5/04/2007	7	400
20481		110	4/27/2007	5/11/2007	14	600
20482		110	4/27/2007	5/11/2007	14	630

Respectfully submitted,  
Southern Arizona Testing Laboratory

E. L. Vick, P.E.  
(kb)

